

Model SDG 15

Product Description

Product Specification

Model No	Description	Nominal Pipe Size, in	Rated Working Pressure		Remarks
			psi	(kPa)	
SDG 15	Split Flange	1 1/2, 2, 2 1/2, 3, 4, 5, 6, 8, 10, 12 76.1, 108, 133, 139, 159, 165 mm	300	(2065)	a, b, c, d, e

Remarks:

a. Minimum schedule cut groove pipe to be joined: 6 in. NPS and smaller - Schedule 40; 8 in. NPS and larger - Schedule 30.

b. Minimum schedule rolled groove pipe to be joined: 6 in. NPS and smaller - Schedule 10S; 8 in. NPS and larger 0.188 in. (5 mm) wall.

c. Approved when supplied with EPDM gasket.

d. Approved when supplied with an ISO PN10 bolt pattern.

e. Approved when used with GB/T3092 regular and extra heavy pipe, ISO 4200, and BS 1387 Medium and Heavy pipe.

Details

Category	Grooved Split Flanges, Flexible
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Shield Fire Safety and Security Ltd
Unit 3 Endeavor Drive, Basildon, Essex, SS14 3WF, United Kingdom
United Kingdom
<http://www.shieldglobal.com>