

SDG 30

Product Description

Product Specification

Model No	End Connection	Nominal Pipe Size, in	Rated Working Pressure		Remarks
			psi	(kPa)	
SDG 30	Cut Groove Rolled Groove	2 x 1 1/2 2 1/2 x 1, 2 3 x 1, 2, 2 1/2 4 x 1, 2 4 x 2 1/2, 3 6 x 3, 4 8 x 6	300	(2065)	a, b, c, d
SDG 30	Cut Groove Rolled Groove	76.1 x 33.7, 1 1/2, 2 3 x 76.1 4 x 76.1 165 x 4 8 x 165	300	(2065)	a, b, c, d

Remarks:

- a. Minimum schedule cut groove pipe to be joined: 6 in. NPS and smaller – Schedule 40; 8 in. NPS and larger – Schedule 30.
- b. Minimum schedule rolled groove pipe to be joined: 6 in. NPS and smaller – Schedule 10S; 8 in. NPS and larger 0.188 in. (5 mm) wall.
- c. Approved when supplied with EPDM gasket.
- d. Approved for use with GB/T3092 regular and extra heavy pipe, ISO 4200, and BS 1387 medium and heavy pipe.

Details

Category	Grooved Couplings, Reducing-Flexible
Class of Work	1920 - Coupling & Fitting, All Type
Approval Standard	FM 1920 - Pipe Couplings and Fittings for Aboveground Fire Protection Systems
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Shield Fire Safety and Security Ltd
 Unit 3 Endeavor Drive, Basildon, Essex, SS14 3WF, United Kingdom
 United Kingdom
<http://www.shieldglobal.com>